



भारत सरकार

Government of India

उपभोक्ता मामले, खाद्य एवं सार्वजनिक वितरण मंत्रालय
Ministry of Consumer Affairs, Food & Public Distribution

उपभोक्ता मामले विभाग
Department of Consumer Affairs

राष्ट्रीय परीक्षण शाला (उत्तरी क्षेत्र)
NATIONAL TEST HOUSE (Northern Region)

कमला नेहरू नगर, गाजियाबाद-201 002
Kamla Nehru Nagar, Ghaziabad - 201002

No. NTH / NR / EL (HV) / 2021 / 0067

Dated : 03.01.2022

To

SIGNAL HAWK ELECTRONICS PVT. LTD.

11, 2nd Floor, Aneja Complex, R-24, Rita Block
Shakarpur, Laxmi Nagar, Delhi-110092

PROVISIONAL TEST REPORT FOR DRY POWER FREQUENCY VOLTAGE WITHSTAND TEST

Sample Description : 11-33 KV FRP DISCHARGE ROD(MODEL-1133, Sr. No. 0001230)

Test Date : 31/12/2021

Customer Reference: SHEPL/Testing/FRP/006 Dated : 21/12/2021.

One No of 11-33 KV Fiber Glass Discharge/Earth Rod was subjected to the following test as per Customer Specification at the premises of National Test House, Ghaziabad.

- 1) Dry Power Frequency Voltage(100 KV AC rms) Withstand Test applied for 1 Minute

The Sample withstood the required voltage and was found to perform satisfactorily in the above mentioned tests.

The Final Report shall be issued in due course of time.

विश्वनाथ गुप्ता / VISHWA NATH GUPTA

वैज्ञानिक री. (विद्युत) / Scientist C (ELECTRICAL)

राष्ट्रीय परीक्षण शाला (उ.क्षे.) / National Test House (NR)

कमला नेहरू नगर, गाजियाबाद / Kamla Nehru Nagar, Ghaziabad